

ADDITIONAL ERRATA POSTING FOR FINAL ACTION AGENDA May 14, 2007

FS65-06/07: Proponent of public comment should read as follows:

Proponent: Rick Thornberry, P.E., The Code Consortium, Inc., representing Cellulose Insulation Manufacturers Association (CIMA)

G113-06/07 Replace table within the reason of original code change with the following:

Construction Type		Height Limit (FT)			
<u>IBC</u>	<u>NBC</u>	<u>IBC*</u>	<u>NBC**</u>		<u>IBC**</u>
I/A	2B	65'	B	85'	85'
			F-1	70'	
			F-2	85'	
			H-3	70'	
			H-4	85'	
			I-1	70'	
			M	70'	
			R-1	70'	
			R-2	70'	
			R-3	70'	
			S-1	70'	
			S-2	85'	
I/B	2C	55'	B	60'	75'
			F-2	60'	
			H-4	60'	
			I-1	60'	
			R-1	60'	
			R-2	60'	
			R-3	60'	
			S-2	60'	
III/A	3A	65'	B	70'	85'
			F-2	70'	
			H-4	70'	
			I-1	70'	
			R-1	70'	
			R-2	70'	
			R-3	70'	
			S-2	70'	
III/B	3B	55'	B	60'	75'
			F-2	60'	
			H-4	60'	
			I-1	60'	
			R-1	60'	
			R-2	60'	
			R-3	60'	
			S-2	60'	
IV	4	65'	B	85'	85'
			F-1	70'	
			F-2	85'	
			H-3	70'	
			H-4	85'	
			I-1	70'	
			M	70'	
			R-1	70'	
			R-2	70'	
			R-3	70'	
			S-1	70'	
			S-2	85'	

VA	5A	50'	B	60'	70'
			F-2	60'	
			H-4	60'	
			I-1	60'	
			R-1	60'	
			R-2	60'	
			R-3	60'	
			S-2	60'	
VB	5B	40'	B	50'	60'
			F-2	50'	
			H-4	50'	
			I-1	55'	
			R-1	55'	
			R-2	55'	
			R-3	55'	
			S-1	50'	
			S-2	50'	

*without 20 foot sprinkler increase

**with 20 foot sprinkler increase